

## SCHEDULE (C).—PART II.—(See § 5.)

CONVERSION for determining the Rates to which Buildings of the First or Dwelling-House Class are to be deemed to belong, and the Thickness of the External and of the Party Walls thereof.

In reference to Height.	In reference to Area.	In reference to Stories.	Rate of Building.	Requisite Thickness of External Walls of each Rate of the First Class.	Requisite Thickness of Party Walls of each Rate of the First Class.
1. If the building be in height not more than 22 feet.	- - If the building do not cover more than 8 squares.	- - If the building contain more than 3 stories.	- - It is to be of the First or Lowest Rate of this Class.	- - And the thickness of the external walls must be, at the least, 8½ inches from the top of the footing to the top of the wall.	- - And the thickness of the party-walls must be, at the least, 12½ inches from the top of the footing to the top of the wall.
2. If more than 22, and not more than 32 feet.	- - or if it cover more than 8 squares.	- - or if it contain more than 3 stories.	- - It is to be of the Second Rate.	- - And the thickness of the external walls must be, at the least, 12½ inches from the top of the footing to the under-side of the gutter-plate; and at the least 8½ inches from the under-side of the plate to the top of the wall.	- - And the thickness of the party-walls must be, at the least, 17½ inches from the top of the footing to the under-side of the second floor; and at the least 12½ inches from the under-side of the second floor to the top of the wall.
3. If more than 32, and not more than 42 feet.	- - or if it cover more than 8 squares.	- - or if it contain more than four stories.	- - It is to be of the Third Rate.	- - And the thickness of the external walls must be, at the least, 17½ inches from the top of the footing to the under-side of the second floor; and, at the least, 12½ inches from the under-side of the second floor to the under-side of the gutter-plate; and, at the least, 8½ inches from the under-side of the gutter-plate to the top of the wall.	- - And the thickness of the party-walls must be, at the least, 17½ inches from the top of the footing to the under-side of the third floor; and, at the least, 12½ inches from the under-side of the third floor to the top of the wall.
4. If more than 42, and not more than 47 feet.	- - or if it cover more than 16 squares.	- - or if it contain more than five stories.	- - It is to be of the Fourth Rate.	- - And the thickness of the external walls must be, at the least, 22 inches from the top of the footing to the under-side of the third floor; and, at the least, 12½ inches from the under-side of the third floor to the under-side of the gutter-plate; and, at the least, 8½ inches from the under-side of the gutter-plate to the top of the wall.	- - And the thickness of the party-walls must be, at the least, 22 inches from the top of the footing to the under-side of the second floor; and, at the least, 17½ inches from the under-side of the second floor to the under-side of the third floor; and at the least 12½ inches from the under-side of the third floor to the top of the wall.
5. If more than 47, and not more than 52 feet.	- - or if it cover more than 16 squares.	- - or if it contain more than six stories.	- - It is to be of the Fifth Rate.	- - And the thickness of the external walls must be, at the least, 22 inches from the top of the footing to the under-side of the second floor; and, at the least, 17½ inches from the under-side of the second floor to the under-side of the gutter-plate; and, at the least, 12½ inches from the under-side of the gutter-plate to the top of the wall.	- - And the thickness of the party-walls must be, at the least, 22 inches from the top of the footing to the under-side of the third floor; and, at the least, 17½ inches from the under-side of the third floor to the top of the wall.
6. If more than 52 feet.	- - or if it cover more than 18 squares.	- - or if it contain more than six stories.	- - It is to be of the Sixth Rate, and of the Third Class.	- - And the thickness of the external walls must be, at the least, 4 inches greater than is hereby required for walls of the fifth rate.	- - And the thickness of the party-wall must be, at the least, four inches greater than is hereby required for walls of the fifth rate.

